TABLE OF CONTENTS

TABLE OF CONTENTS 1

INTRODUCTION 2

BACKGROUND 2

FUME HOOD DESIGN AND CONSTRUCTION 3

- VARIABLE AIR VOLUME FUME HOODS 3
- RECIRCULATING HOODS 3
- SPECIAL LABORATORY FUME HOODS 4
- SUPPLY AIR 4
- AUXILLARY SUPPLIED AIR HOODS 4
- EXHAUST STACK DISCHARGE AND EXIT VELOCITIES 5

NEW HOOD PURCHASE SPECIFICATIONS AND EVALUATIONS 5

PERFORMANCE TESTING OF FUME HOOD EXHAUST SYSTEMS AND BIOLOGICAL SAFETY CABINETS 5

- TESTING CRITERIA 6
  - FACE VELOCITY 6
  - FLOW VISUALIZATION QUALITATIVE TESTS 7
  - FACE VELOCITY MONITORING 7

PROCEDURES FOR TESTING FUME HOOD SYSTEMS 7

USE OF LABORATORY HOODS AND BIOLOGICAL SAFETY CABINETS 9

OVERSIGHT 10

- ENVIRONMENTAL HEALTH AND SAFETY BOARD 10
- FACILITIES PLANNING 11
- DEPARTMENT HEAD 11
- PERSONNEL USING FUME HOODS 11

DECONTAMINATION AND REMOVAL OF FUME HOOD SYSTEMS OR BIOLOGICAL SAFETY CABINETS 12

CONTRACTORS WORKING WITH FUME HOODS AND ASSOCIATED FANS AND DUCTWORK 12

Appendix A - PUBLICATIONS 13

Appendix B -- DEFINITIONS 15

Appendix C – LOCAL EXHAUST VENTILATION SYSTEMS TESTING, BALANCING, AND OPERATIONAL CHECK LIST 17

Although system performance depends heavily on the above design elements it must be noted that the fume hood performance in a room is affected by room layout and supply air distribution. System 0 58 -s4p>JoTd ( )TBDC BT 04.3

measurements, flow visualization qualitative tests, and possibly additional containment tests as warranted

When a fume hood fails to meet acceptable performance requirements the hood will be declared out of service. Fume hood systems that do not meet these requirements must not be used. The responsibility for fume hood system evaluations lies within the Facilities Department.

(e)4 (r)-7 chedt

FLOW VISUALIZATION QUALITATIVE TESTS

Flow visualization qualitatively tests a hood's ability to contain vapors. This test consists of a small local challenge (use of a smoke tube or dry ice) and a gross challenge (use of a smoke candle or smoke generator) to the hood. Smoke released in the hood is visually monitored to determine if hood or associated duct work leaks during operation.

Containment must be verified for all hoods using a minim of one of the described visual methods (i.e. smoke tube or dry ice). Poor results would dictate that advanced testing protocols using tracer gas containment test methods, including the ANSI/ASHRAE 110 "Method of Testing and Performance of Laboratory Fume Hoods" may be employed in certain instances where hood performance is questionable during operation.

FACE VELOCITY MONITORING

All fume hoods shall include some means of monitoring face velocity with a visual and audio alarm. After the laboratory air handling system has been balanced, the "low-flow" of the air velocity and/or static pressure sensors shall be adjusted and set to activate the alarm whenever the face velocity of any fume hood falls 10% or more from its baseline average face velocity with the sash at 18".

PROCEDURES FOR TESTING FUME HOOD SYSTEMS

1. General room ventilating systems, both supply and exhaust, including fume hood exhaust, must meet Facilities Planning Design Specifications and shall be in full normal operation. Airflow systems in the laboratory shall be properly tested and balanced prior to this test. This includes calibration of airflow controls, calibration of automatic temperature controls, balance of supply air, etc. Laboratories must be under negative pressure relative to corridor unless special design conditions prevail.
2. Hoods are tested in fully open position, half open position, and 25% open position.
3. All other hoods in the same room are in half-open position.
4. All other hoods on the same floor exhaust system are in half-open position.
5. The hood being tested should be empty.
6. The doors to the laboratory will be closed
7. When adjustments are made to hood sashes, supply and exhaust air in the room will be allowed to stabilize before testing is done
8. Hood monitor is calibrated and not in alarm.

Determination of Average Face Velocity for Variable Air Volume (VAV) Hoods

Figure showing common baffle locations

CDC/NIH's publications Biosafety in Microbiological and Biomedical Laboratories and Primary Containment for Biohazards: Selection, Installation, and Use of Biological Safety Cabinets provide additional information on the use of biological safety cabinets Horizontal and vertical laminar flow clean benches are not biological safety cabinets These clean benches provide a very clean environment for the manipulation of non-hazardous materials and can be used for activities such as the dust assembly of sterile equipment or electronic devices Since the operator sits in the downstream exhaust from the clean bench, this equipment must never be used for the handling of toxic, radioactive, infectious, or sensitizing materials

OVERSIGHT

ENVIRONMENTAL HEALTH AND SAFETY BOARD

- Maintains a list of competent personnel or contractors to certify fume hoods
- Inspects the entire fume hood operating systems including the fume hood, associated duct work, exhaust blowers, and stacks
- Places a sticker on fume hoods with average face velocity if the hood operating systems "PASS"
- Places a "DO NOT USE" sign on the hood sash if the hood operating system does "NOT PASS"
- Puts in a work order on behalf of the department head to Facilities Department for repair
- Notifies the Department Head, Environmental Health and Safety Coordinator, and Facilities Department of any hoods which are placed "OUT OF SERVICE"

FACILITIES PLANNING

- Make all necessary repairs/modifications, in a timely manner, to the fume hood operating system, and any associated equipment which affects the fume hood operating system in order to make the entire system safe to use.
- Notify CHBO after all repairs/modifications are completed. CHBO will request system retest
- Notify CHBO on a monthly basis in writing as to the status of repair/replacement of fume hoods based on work orders/work requests submitted.

DEPARTMENT HEAD

- Ensure that any fume hoods which are placed "OUT OF SERVICE" will not be used until notified by facilities that the hood can be used.
- Ensure that repairs/modifications are completed in a timely manner to any fume hoods which have been placed "OUT OF SERVICE".
- Notify CHBO and Facilities Planning of any fume hoods which are not operating properly.

PERSONNEL USING FUME HOODS

- Follow all safety and health procedures specified in the Laboratory Chemical Hygiene and Safety Manual and by the faculty supervisor in the laboratory.
- Attend all required health and safety training sessions.
- Do not use fume hoods which are "OUT OF SERVICE".
- Report fume hoods which are not operating properly, accidents, unhealthy, and unsafe conditions to the faculty supervisor.
- Notify faculty supervisor of any pre-existing health conditions that could lead to serious health situations when using a fume hood.
- Do not put your head in the hood when contaminants are being generated.
- Hoods should not be routinely used as a waste disposal mechanism for volatile materials. If a flammable storage cabinet is not available, the hood may be used to store volatile waste awaiting to be picked up by

STANDARDS FOR THE DESIGN, CONSTRUCTION, MAINTENANCE AND USE OF LABORATORY FUME HOODS

Appendix A - PUBLICATIONS

ACGIH. "Industrial Ventilation

OSHA

lpm: liters per minute (ANSI/ASHRAE 110, 1995)

Makeup Air: outside air drawn into a ventilation system to replace exhaust air (ANSI/AIHA Z9.5, 2003). Makeup air MUST always be provided when any exhaust system is designed and installed

perchloric acid hood: a fume hood constructed with water wash so it is safe for use with perchloric acid or other reagents that might form flammable or explosive compounds with organic materials of construction (ANSI/AIHA Z9.5, 1992).

Recirculation: air withdrawn from a space, passed through a ventilation system, and delivered again to an occupied space (ANSI/AIHA Z9.5, 2003).

Reentry: The flow of contaminated air that has been exhausted from a space back into the space through air intakes or openings in the walls of the space (ANSI/AIHA Z9.5, 1992).

Replacement Air: see makeup air

Return Air: air being returned from a space to the ventilation fan that supplies a space (ANSI/AIHA Z9.5, 2003).

Special Purpose Hood: an exhaust hood, not otherwise classified, for a special purpose such as but not limited to - capturing gases from equipment such as atomic absorption, gas chromatographs, liquid pouring or mixing stations, and heat sources (ANSI/AIHA Z9.5, 2003).

Variable Air Volume Fume Hood: a fume hood designed so the exhaust volume is varied in proportion to the opening of the hood face by changing the speed of the exhaust blower or by operating a damper in the exhaust hood (ANSI/AIHA Z9.5, 2003).

Velocity: speed and direction of motion (ANSI/AIHA Z9.5, 2003).

Walk-in hood: a fume hood designed to be floor mounted with sash and/or doors for closing the open face (ANSI/AIHA Z9.5, 2003).

Appendix C – LOCAL EXHAUST VENTILATION SYSTEMS TESTING, BALANCING, AND OPERATIONAL CHECK LIST

Item No.	Local Exhaust Ventilation Systems Testing, Balancing, and Operational Check List	Date Completed
1.	General room ventilation requirements for laboratory and	

Item No.	Local Exhaust Ventilation Systems Testing,

Item No.	Local Exhaust Ventilation Systems Testing, Balancing, and Operational Check List	Date Completed